

EC Declaration of Conformity

Document no. DZ.LI-24.ALW.Z2.ENG

Manufacturer: **APLISENS S.A.**,
ul. Morelowa 7, 03-192 Warszawa

We hereby acknowledge, that:

Smart temperature transmitters **LI-24ALW** in all versions comply with directive

- **EMC – 2004/108/EC**

The following standard was applied EN 61326-1:2006.

Smart temperature transmitters **LI-24ALW** in intrinsically safe versions comply with directive

- **ATEX – 94/9/EC**

Intrinsically safe versions of transmitters are marked with the following certificate marking:

II 1/2G Ex ia IIC T4-T6 Ga/Gb
I M1 Ex ia I Ma (version with ss316 housing)
II 1D Ex ia IIIC T105°C Da

Certificate no. FTZÚ 13 ATEX 0205X

Certificates were issued by Notified Body no.1026, Physical Technical Testing Institute,
Pikartska 7, 716 07 Ostrava Radvanice.

The following standards were applied: EN 60079-0:2012, EN 60079-11:2012, EN 60079-26:2007,
EN 50303:2000.

Smart temperature transmitters **LI-24ALW** in explosion-proof versions comply with directive

- **ATEX – 94/9/EC**

Explosion-proof transmitters are marked with the following certificate marking:

II 2(1)G Ex d [ia Ga] IIC T4/T5T6 Gb
II 2(1)D Ex t [ia Da] IIIC T105°C Db
I M2 Ex d [ia Ma] I Mb (version with ss316 housing)
or
II 2G Ex d IIC T* Gb
II 2D Ex t IIIC T* Db
I M2 Ex d I Mb (version with ss316 housing)

Certificate no. KDB 14 ATEX 0118X

Certificates were issued by Notified Body no.1453, Central Mining Institute,
Plac Gwarków 1, 40-166 Katowice.

The following standards were applied: EN 60079-0:2012/A11:2013, EN 60079-1:2007, EN 60079-11:2012,
EN 60079-26:2007, EN 60079-31:2009.

Warsaw, 20.11.2014

Adam Żurawski
General Manager

