

EU Declaration of Conformity

issued under the sole responsibility of the manufacturer

The object of this declaration: Smart level probes **SGE-25.Smart, SGE-25S.Smart, SGE-25C.Smart**

Manufacturer: **APLISENS S.A.,
ul. Morelowa 7,
03-192 Warszawa**

We hereby declare under the sole responsibility, that the object of the declaration defined above comply with relevant Union harmonization legislation.

Smart level probes **SGE-25.Smart, SGE-25S.Smart, SGE-25C.Smart** in all versions comply with directives:

- **EMC – 2014/30/EU** dated 26 February 2014

Conformity assessment procedure: module A.

The following standards were applied EN 61326-1:2013, EN 61326-2-3:2013.

- **RoHS – 2011/65/EU** dated 08 June 2011

Conformity assessment procedure: module A, according to Decision No 768/2008/EC of the European Parliament and of the Council.

The following standard was applied: EN IEC 63000:2018.

Smart level probes **SGE-25.Smart, SGE-25S.Smart, SGE-25C.Smart** in intrinsically safe versions comply with directive:

- **ATEX – 2014/34/EU** dated 26 February 2014

Transmitters in intrinsically safe versions are marked with the following certificate marking:

II 1G Ex ia IIC T4/T5/T6 Ga

II 1G Ex ia IIB T4/T5/T6 Ga (for probe with teflon-shielded cable)

I M1 Ex ia I Ma

KDB 11 ATEX 140X

Certificate (Module B) was issued by Notified Body no.1453, Central Mining Institute, Plac Gwarków 1, 40-166 Katowice.

The following standards were applied: EN IEC 60079-0:2018, EN 60079-11:2012,
EN 50303:2000.

Notification of quality assurance is issued (Module D) by Notified Body no.1453, Central Mining Institute, Plac Gwarków 1, 40-166 Katowice.

Warsaw, 01.07.2021



Adam Żurawski
General Manager